

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 132

Date: 12/06/2025

It is certified that an inspection team headed by SANJAY PANDEY.....
from EXECUTIVE ENGINEER..... PHED inspected the **Sai Public School**, In front of Shiv Mangalyam Marriage Garden, Shardapuram, Rewa (M.P.)
onJUNE 2025..... and on the basis of Water Test
Report (Attached) bearing no ..26..... dated..02/06/2025.....
of (PHED Lab) certified that the **Sai Public School** has
safe drinking water facilities for the students and members of staff of the institution.
Sai Public School also maintains the hygienic sanitation condition in the school
building & the campus as per norms prescribed by the Central/U.T. Govt.

This certificate is valid till1 year.....

Signature with Seal :

[Signature]
Executive Engineer
Public Health Engg. Division
Rewa (M.P.)

Name

Sanjay Pandey
: Executive Engineer

Designation

: Executive Engineer.....
Public Health Engg. Division

Name & Address of the office/Department :

To

Sai Public School,

In front of Shiv Mangalyam Marriage Garden,
Shardapuram, Rewa (M.P.) - 486001

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

Digitally signed by admin
Date: 2025.07.31 19:37:26 +05:30
Reason: reason
Location: location

District Laboratory Division Rewa
Public Health Engineering Department Rewa
ANALYSIS REPORT

Types of Sample <u>T.W.</u>	
PARTICULARS OF SENDER <u>Principal</u>	
PARTICULARS OF SAMPLE <u>Sai public school</u> Collected/Not Collected by PHBD	
Sample No.	Place of collection and details of sample Date
<u>(07)</u>	<u>Sai public school Ghis Manglyam Mung Gian Jan Rewa (M.P.)</u>

PARTICULARS TO BE FILLED IN THE LABORATORY	
Date of Receipt <u>02/06/2025</u>	Time of Receipt
Lab reference No.	Tested On <u>03/06/25</u>

NATURE OF STUDY - CHEMICAL & BACTERIOLOGICAL ANALYSIS

S.No.	Characteristics	Unit	As per BIS -10500, 2021 for Drinking Water		Result							
			S.N.	Requirement (Desirable Limit)	Permissible limit in the absence of Alternate Source	Sample 1	Sample 2	Sample 3	Sample 4			

PHYSICAL TESTS

1	Temperature	Oc	22°				
2	Turbidity	NTU	1	5.0	1.0				
3	Colour	Hazen Units	5	15	10				
4	Odour	Unobjectionable	Objectionable					

CHEMICAL TESTS

5	pH	pH Scale	6.5 to 8.5	No Relaxation	8.85				
6	Total Hardness as CaCO3	mg/l	200	600	248				
7	Calcium as Ca	mg/l	75	200	58.84				
8	Magnesium as Mg	mg/l	30	100	27.27				
9	Alkalinity as Ca	mg/l	200	600	97.5				
10	Chloride as Cl	mg/l	250	1000	12.49				
11	Nitrate as NO3	mg/l	45	45	10.5				
12	Total Dissolved S	mg/l	500	2000	510				
13	Iron	mg/l	1.0	1	0.3				
14	Sulphate as SO4	mg/l	200	400	8				
15	Fluoride as F	mg/l	1	1.5	0.3				
16					0.00				

Digitally signed by admin
Date: 2025.07.31 19:37:26 +05:30
Reason: reason
Location: location

BACTERIOLOGICAL TEST						
18	Residual Chloride as Cl ₂	mg/l	0.2	1.0	Nil	
19	MPN of Coliform	Per 100 ml	Nil	Nil	0.00	
20	Faecal Coliform	Per 100 ml				

Note:- The figures indicated under the column "Requirement (Desirable Limit)" the limit upto which water is generally acceptable to the consumers, Figures in excess of those mentioned under "Requirement (Desirable Limit)" the water not acceptable, but still may be tolerated in the absence of an alternative and better source byt upto the limits indicatd under column "Permissible limit in the absence of Alternate Source" above which the course will have to rejected (Guideline values for Drinking water as Per BIS 10500)

for ADPM
 Signature of Analyst
 Remarks if any.

G.V.T.
 Chemist
 District Laboratory
 M.E.D. Division Rewa (M.P.)

[Signature]
 Lab Incharge
 District Laboratory PHED Rewa (M.P.)